

## BRE Test Report

**Weathertightness test to BS EN 14351-1:2006 +A1:2010 clauses 4.2, 4.5 and 4.14 on a Duplus Architectural Systems glazed Pyramid rooflight**

Prepared for: Peter Gregory  
Date: 08 December 2016  
Report Number: P105101-1001 Issue 2

BRE  
Watford, Herts  
WD25 9XX

Customer Services 0333 321 8811

From outside the UK:  
T + 44 (0) 1923 664000  
F + 44 (0) 1923 664010  
E enquiries@bre.co.uk  
www.bre.co.uk

Prepared for:  
Mr. Peter Gregory BA (Hons)  
Managing Director  
Duplus Architectural Systems Ltd  
370 Melton Road  
Leicester  
LE4 7SL



0578

BRE is not UKAS accredited to make opinions and interpretation. Any opinions and interpretations included as part of this report are clearly marked as such.



---

## Prepared by

---

Name Malcolm Pound

Position Senior Consultant and Laboratory Manager, Fire and Building Technology Group

Date 08 December 2016

Signature

A handwritten signature in black ink that reads "M. C. Pound".

---

## Authorised by

---

Name Dr. Paul Blackmore

Position Associate Director, Fire and Building Technology Group

Date 08 December 2016

Signature

A handwritten signature in black ink that reads "P. Blackmore".

This report is made on behalf of Building Research Establishment Ltd (BRE) and may only be distributed in its entirety, without amendment, and with attribution to BRE to the extent permitted by the terms and conditions of the contract. Test results relate only to the specimens tested. BRE has no responsibility for the design, materials, workmanship or performance of the product or specimens tested. This report does not constitute an approval, certification or endorsement of the product tested and no such claims should be made on websites, marketing materials, etc. Any reference to the results contained in this report should be accompanied by a copy of the full report, or a link to a copy of the full report.

BRE's liability in respect of this report and reliance thereupon shall be as per the terms and conditions of contract with the client and BRE shall have no liability to third parties to the extent permitted in law.

## BRE P105101-1001 Summary of weathertightness test results – Pyramid rooflight

The test results for the 2042 mm x 2042 mm specimen of Duplus Architectural Systems Ltd Pyramid rooflight are summarised in Table 1 below for tests at a UK exposure category of '2000+'.

BS EN 14351-1:2006 +A1:2010 is the product standard that identifies mandated and non-mandated characteristics for windows and external pedestrian doors for the European market, and it enables products to be CE marked. Designers, specifiers, manufacturers and end users need to identify those characteristics and performance levels appropriate for the selected end use. These will vary from site to site and from country to country.

To avoid uneconomical and inappropriate specifications for the UK market recommended levels of performance have been identified. These performance levels (in this case for weathertightness) are in the National Application Document (NAD) BS 6375-1:2015.

The tests to methods specified in BS 6375-1:2015 are BS EN 1026, 1027 and 12211, they measure the weathertightness of the specimens in terms of air permeability, watertightness and resistance to wind load respectively. Classification of the results is based on BS 6375-1:2015 and BS EN 12207, 12208, 12210.

Air permeability		Watertightness		Resistance to wind loads	
Requirements	Results	Requirement	Results	Requirements	Results
Class 2 at 300 Pa or Classes 3 and 4 at 600 Pa	Met Class 4 for the average of positive and negative test results	Class 7A at 300 Pa	Class 9A at 600 Pa	Class AE2400 P1 = 2400 Pa P2 = 1200 Pa P3 = 3600 Pa	Met all of the requirements for Class AE2400

**Table 1. Summary of weathertightness test results**

Furthermore, the test results from the specimen of Pyramid rooflight tested and described in test report P105101-1001 also apply to the versions shown in Figures A4 and A5 in the annex to that report because they have similar sealing arrangement and are at least as stiff as the version tested.

The results also apply to the Pyramid rooflight with the glazing method described in P105101-1001, when glazed with 4 mm thick glass, up to a maximum product size of 1.0 m wide x 2 m long.